

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

R.No.E1/002416/2025

Date:28.04.2025

It is certified that an inspection team headed by **C.K.Vishwanatham , Block Health Supervisor** from **Public Health Department, Ranipet** inspected the **Edify World School, No:55, Chithathur Village, Walaja – Sholingur Road, Sholingur Taluk, Ranipet District-632501** on **25.04.2025** (date of inspection) and found that the **Edify World School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central State/ U.T. Govt.

The above is valid for a period of **one year** from **13.05.2025** to **13.05.2026**

Signature with Seal:

Name:

Designation:

Name & Address of the Office/Department:


ககதர ககதர மேற்பார்வைப்பார்வர்
ஓரக ஆரம்ப ககதர திதையம்
கொடைக்கல் - 631102
மேலநிலை துறக்கல், மலையிலுக்கல், மலையிலுக்கல்

To

The Correspondent,
Edify World School,
No:55 Chithathur Village,
Walaja-Sholingur Road,
Sholingur Taluk,
Ranipet District-632501.


CORRESPONDENT
Edify World School,
Ranipet.



TEST WATER BEFORE TASTE

twadlabphotos@gmail.com
Ph : 0416 - 2215168**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****District Level Water Testing Laboratory**

Opp. To Muthu Mandapam, Old Katpadi Road, Vellore - 632 004.

TEST REPORTTO:
EDIFY WORLD SCHOOL,
Chitator Village,
Walaja Taluk,
Ranipet District

Lr.No.67147-67147A/JWA/Lab/VLR/2025/dt:13.05.2025.

Sir,

Ref : Lr.No: Dated. 12.05.2025

2.T.O Invoice No: 11370,Dated:12.05.2025. For Rs: 1652/-

The result of analysis for the water samples sent under reference is enclosed.

Scheme: PVT

Date of Collection: 12.05.2025.

Source : Bore Well

Date of Receipt: 12.05.2025.

Location:67147/67147A: School Back Side,Chitator Village,Walaja

BIS 10500:2012	Acceptable Limit	Maximum permissible limit in the absence of alternative source.	Result
I. PHYSICAL EXAMINATIONS			67147
1. Appearance			Clear
2. Colour			Colourless
3. Odour	Agreeable	Agreeable	None
4. Turbidity NTU		5	0
5. Total dissolved solids Mg/L	500	2000	865
6. Electrical conductivity micro mho/cm			1235
II. CHEMICAL EXAMINATIONS			
7. pH	6.5-8.5	6.5-8.5	7.35
8. Alkalinity Ph as CaCO ₃ mg/L			0
9. Alkalinity Total as CaCO ₃ mg/L	200	600	252
10. Total Hardness as CaCO ₃ mg/L	200	600	364
11. Calcium as Ca mg/L	75	200	74
12. Magnesium as Mg/L	30	100	43
13. Sodium as Na mg/L			-
14. Potassium as K mg/L			-
15. Iron Total as Fe mg/L	0.3	1.0	0.00
16. Manganese as Mn mg/L	0.1	0.3	0.00
17. Free Ammonia as NH ₃ mg/L	0.5	0.5	0.00
18. Nitrite as NO ₂ mg/L			0.00
19. Nitrate as NO ₃ mg/L	45	45	8
20. Chloride as Cl mg/L	250	1000	178
21. Fluoride as F mg/L	1.0	1.5	0.4
22. Sulphate as SO ₄ mg/L	200	400	92
23. Phosphate as PO ₄ mg/L			0.00
24. Tids Test 4Hrs.as O ₂ mg/l			0.0
III. BACTERIOLOGICAL EXAMINATION (M.F.Technique)			67147A
Fecal Coliform(100ml)			0

CORRESPONDENT
Edify World School,
Ranipet.

Report:67147: The water sample is chemically Potable.

Report:67147A: The water sample is Bacteriologically Not contaminated.

B. S. S. S. S.
13/5/25
Junior Water Analyst
TWAD Board
District Water Testing Laboratory
Vellore - 632 004.

Kamf
CORRESPONDENT
Edify World School,
Ranipet.